

KVALITETSKONTROL



Hedevej 8, 7362 Hampen | Sepstrupvej 39A, 8653 Them
Tlf: 40 33 65 75 | CVR 35 48 15 75 | www.asklevstenoggrus.dk

Sigteanalyse

Udtaget dato: 20.08.2018
Vare: Stabilgrus 0-40 mm.
Prøvenr.: 18-009
Laboratorie: Gustav H. Christensen
Udtaget af: MS
Udtagnings sted: Asklev

Sigtestørrelse	Gennemfald %
45,00	100,0
31,50	94,0
16,00	54,0
11,20	46,0
8,00	38,0
5,60	33,0
4,00	31,0
2,00	29,0
1,00	26,0
0,50	19,0
0,25	9,0
0,125	3,0
0,063	2,0

U-tal, d60:d10=	67,0	Vandindhold: <16 mm = 6,9%
		Methylen blå: 1,5

Kornkurve

